

Electric Vehicle Infrastructure 2019 Reach Code Language CALGreen Format

Definitions:

EV Capable: A parking space linked to a listed electrical panel with sufficient capacity to provide at least 110/120 volts and 20 amperes to the parking space. Raceways linking the electrical panel and parking space only need to be installed in spaces that will be inaccessible in the future, either trenched underground or where penetrations to walls, floors, or other partitions would otherwise be required for future installation of branch circuits. Raceways must be at least 1" in diameter and may be sized for multiple circuits as allowed by the California Electrical Code. The panel circuit directory shall identify the overcurrent protective device space(s) reserved for EV charging as "EV CAPABLE." Construction documents shall indicate future completion of raceway from the panel to the parking space, via the installed inaccessible raceways.

Level 1 EV Ready Circuit: A parking space served by a complete electric circuit with a minimum of 110/120 volt, 20-ampere capacity including electrical panel capacity, overprotection device, a minimum 1" diameter raceway that may include multiple circuits as allowed by the California Electrical Code, wiring, and either a) a receptacle labelled "Electric Vehicle Outlet" with at least a ½" font adjacent to the parking space, or b) electric vehicle supply equipment (EVSE).

Level 2 EV Ready Circuit: A parking space served by a complete electric circuit with 208/240 volt, 40-ampere capacity including electrical panel capacity, overprotection device, a minimum 1" diameter raceway that may include multiple circuits as allowed by the California Electrical Code, wiring, and either a) a receptacle labelled "Electric Vehicle Outlet" with at least a ½" font adjacent to the parking space, or b) electric vehicle supply equipment (EVSE) with a minimum output of 30 amperes.

Electric Vehicle Charging Station (EVCS): A parking space that includes installation of electric vehicle supply equipment (EVSE) with a minimum output of 30 amperes connected to a Level 2 EV Ready Circuit. EVCS installation may be used to satisfy a Level 2 EV Ready Circuit requirement.

SECTION 4 RESIDENTIAL MANDATORY MEASURES

4.106.4 Electric vehicle (EV) charging for new construction. New construction shall comply with Sections 4.106.4.1 and 4.106.4.2 to facilitate future installation and use of EV chargers.

Electric Vehicle Infrastructure 2019 Reach Code Language CALGreen Format

Exceptions:

1. Where there is no commercial power supply.
2. Accessory Dwelling Units (ADU) and Junior Accessory Dwelling Units (JADU) without additional parking facilities, unless the electrical panel is upgraded, or a new panel is installed in which case only the electrical capacity requirements apply.

4.106.4.1 New one- and two-family dwellings and town- houses with attached private garages.

For each dwelling unit, install two Level 2 EV Ready Circuits.

Exception: For each dwelling unit with only one parking space, install a Level 2 EV Ready Circuit.

4.106.4.2 New multifamily dwellings. The following requirements apply to all new multifamily dwellings:

1. For multifamily buildings with less than or equal to 20 dwelling units, one parking space per dwelling unit with parking shall be provided with a Level 2 EV Ready Circuit.
2. When more than 20 multifamily dwelling units are constructed on a building site:
 - a. 75% of the dwelling units with parking space(s) shall be provided with at least one Level 2 EV Ready Circuit. Calculations for the required minimum number of Level 2 EV Ready spaces shall be rounded up to the nearest whole number.
 - b. In addition, each remaining dwelling unit with parking space(s) shall be provided with at least a Level 2 EV Capable Circuit.

Notes:

1. Load balancing systems may be installed to increase the number of EV chargers or the amperage or voltage beyond the minimum required. Load balancing does not allow installing less electrical panel capacity than would be required without load balancing.
2. Installation of Level 2 EV Ready Circuits above the minimum number required level may offset the minimum number Level 1 EV Ready Circuits required on a 1:1 basis.

Electric Vehicle Infrastructure 2019 Reach Code Language CALGreen Format

3. The requirements apply to multifamily buildings with parking spaces including: a) assigned or leased to individual dwelling units, and b) unassigned residential parking.

4.106.4.2.1.1 Electric vehicle charging stations (EVCS). When EV chargers are installed, EV spaces required by Section 4.106.4.2.2, Item 3, shall comply with at least one of the following options:

1. The EV space shall be located adjacent to an accessible parking space meeting the requirements of the *California Building Code*, Chapter 11A, to allow use of the EV charger from the accessible parking space.
2. The EV space shall be located on an accessible route, as defined in the *California Building Code*, Chapter 2, to the building.

Exception: Electric vehicle charging stations designed and constructed in compliance with the California Building Code, Chapter 11B, are not required to comply with Section 4.106.4.2.1.1 and Section 4.106.4.2.2, Item 3.

Note: The Division of the State Architect provides guidance on exemptions from Chapter 11B EV infrastructure accessibility requirements, such as buildings that are not subject to Chapter 11B and assigned parking spaces at buildings that are subject to Chapter 11B.

4.106.4.2.2 Electric vehicle charging space (EV space) dimensions. The EV spaces shall be designed to comply with the following:

1. The minimum length of each EV space shall be 18 feet (5486 mm).
2. The minimum width of each EV space shall be 9 feet (2743 mm).
3. One in every 25 EV spaces, but not less than one, shall also have an 8-foot (2438 mm) wide minimum aisle. A 5-foot (1524 mm) wide minimum aisle shall be permitted provided the minimum width of the EV space is 12 feet (3658 mm). Surface slope for this EV space and the aisle shall not exceed 1 unit vertical in 48 units

4.106.4.2.3 Good Design Practices. For all projects subject to California Code of Regulations Title 24, Part 2, Chapter 11B, construction documents shall indicate how many accessible EVCS would be required as per Title 24, Chapter 11B to convert all Level 2 EV Ready Circuits required under section 4.106.4 to EVCS. Construction documents shall also demonstrate that the facility is

Electric Vehicle Infrastructure 2019 Reach Code Language CALGreen Format

designed such that compliance with accessibility standards, including Chapter 11B accessible routes, will be feasible for the required accessible EVCS at the time of EVCS installation. Surface slope for any area designated for accessible EVCS shall meet slope requirements in Chapter 11B and vertical clearance requirements in Chapter 11B at the time of original building construction.¹

Note: Section 11B-812 of the 2016 California Building Code requires that a facility providing EVCS for public and common use also provides one or more accessible EVCS as specified in Table 11B-228.3.2.1. Chapter 11B applies to certain facilities including, but not limited to, public accommodations and publicly funded housing (see Section 1.9 of Part 2 of the California Building Code). Section 11B-812 requires that “Parking spaces, access aisles and vehicular routes serving them shall provide a vertical clearance of 98 inches (2489 mm) minimum.” It also requires that parking spaces and access aisles meet maximum slope requirements of 1 unit vertical in 48 units horizontal (2.083 percent slope) in any direction at the time of new building construction or renovation. Section 11B-812.5 contains accessible route requirements. In addition, Title 24 Part 11 Section 4.106.4.2 requires that developers meet certain aspects of accessibility requirements at the time of new construction for a limited number of parking spaces.

SECTION 5

NONRESIDENTIAL MANDATORY MEASURES

5.106.5.3 Electric vehicle (EV) charging. New construction shall comply with Section 5.106.5.3.1 or Section 5.106.5.3.2 to facilitate future installation and use of EV chargers.

Exception: Where there is no commercial power supply.

Notes:

1. Load balancing systems may be installed to increase the number of EV chargers or the amperage or voltage beyond the minimum requirements in this code. The option does not allow for installing less electrical panel capacity than would be required without load balancing.

Electric Vehicle Infrastructure 2019 Reach Code Language CALGreen Format

5.106.5.3.1 Office buildings: In nonresidential new construction buildings designated primarily for office use:

1. When 10 or more parking spaces are constructed, 20% of the available parking spaces on site shall be equipped with Level 2 EVCS;
2. An additional 30% shall be at least Level 2 EV Capable.

Calculations for the required minimum number of spaces equipped with Level 2 EVCS, Level 1 EV Ready spaces and EV Capable spaces shall all be rounded up to the nearest whole number

Construction plans and specifications shall demonstrate that all raceways shall be a minimum of 1" and sufficient for installation of EVCS at all required Level 1 EV Ready and EV Capable spaces; Electrical calculations shall substantiate the design of the electrical system to include the rating of equipment and any on-site distribution transformers, and have sufficient capacity to simultaneously charge EVs at all required EV spaces including Level 1 V Ready and EV Capable spaces; and service panel or subpanel(s) shall have sufficient capacity to accommodate the required number of dedicated branch circuit(s) for the future installation of the EVSE.

5.106.5.3.2 Other nonresidential buildings: In nonresidential new construction buildings that are not designated primarily for office use, such as retail or institutional uses:

1. When 10 or more parking spaces are constructed, 15% of the available parking spaces on site shall be equipped with Level 2 EV Ready;

Calculations for the required minimum number of spaces equipped with Level 2 EV Ready spaces shall be rounded up to the nearest whole number

Exception: Installation of each Direct Current Fast Charger with the capacity to provide at least 80 kW output may substitute for 15 EV Ready spaces after a minimum of 15 Level 2 EV Ready spaces are installed.

5.106.5.3.3 Good Design Practices. For all projects subject to Title 24, Part 2, Chapter 11B, construction documents shall indicate how many accessible EVCS would be required under the California Code of Regulations Title 24, Chapter 11B, if applicable, in order to convert Level 1 EV Ready infrastructure to EVCS. Construction documents shall also demonstrate that the facility is designed such that compliance with accessibility standards, including Chapter 11B accessible routes, will be feasible for the required accessible EVCS at the time of EVCS installation. Surface slope for any area designated for accessible EVCS shall meet

Electric Vehicle Infrastructure 2019 Reach Code Language CALGreen Format

slope requirements in Chapter 11B and vertical clearance requirements in Chapter 11B at the time of original building construction.

5.106.5.3.5 Clean Air Vehicle Parking Designation. EVCS qualify as designated parking as described in Section 5.106.5.2 Designated parking for clean air vehicles.

Notes:

1. The California Department of Transportation adopts and publishes the California Manual on Uniform Traffic Control Devices (California MUTCD) to provide uniform standards and specifications for all official traffic control devices in California. Zero Emission Vehicle Signs and Pavement Markings can be found in the New Policies & Directives number 13-01. www.dot.ca.gov/hq/traffops/policy/13-01.pdf.
2. See Vehicle Code Section 22511 for EV charging spaces signage in off-street parking facilities and for use of EV charging spaces.
3. The Governor's Office of Planning and Research published a Zero-Emission Vehicle Community Readiness Guidebook which provides helpful information for local governments, residents and businesses. www.opr.ca.gov/docs/ZEV_Guidebook.pdf.
4. Section 11B-812 of the 2016 California Building Code requires that a facility providing EVCS for public and common use also provide one or more accessible EVCS as specified in Table 11B-228.3.2.1. Chapter 11B applies to certain facilities including, but not limited to, public accommodations and publicly funded housing (see section 1.9 of Part 2 of the California Building Code). Section 11B-812 requires that "Parking spaces, access aisles and vehicular routes serving them shall provide a vertical clearance of 98 inches (2489 mm) minimum." It also requires that parking spaces and access aisles meet maximum slope requirements of 1 unit vertical in 48 units horizontal (2.083 percent slope) in any direction at the time of new building construction or renovation. Section 11B-812.5 contains accessible route requirements.