



CITY OF HAYWARD

Hayward City Hall
777 B Street
Hayward, CA 94541
www.Hayward-CA.gov

Cover Memo

File #: CONS 18-605, **Version:** 1

DATE: September 18, 2018

TO: Mayor and City Council

FROM: Director of Utilities & Environmental Services

SUBJECT

Water Pollution Control Facility-Valve Operating Mechanism Replacement: Authorization for City Manager to Execute a Sole Source Purchase of REXA Actuators

RECOMMENDATION

That Council adopts the attached resolution authorizing the City Manager to execute a sole source purchase of REXA actuators from REXA Electraulic Actuation, in an amount not to exceed \$235,000.

SUMMARY

There are fourteen REXA valve operating mechanism actuators currently in operation at the Water Pollution Control Facility (WPCF). The performance of these actuators is essential for the proper function of two biological treatment unit processes. As part of the FY 2017 Capital Improvement Program, Council approved funding for the WPCF REXA Valve Replacement Project, 07692, in the amount of \$235,000. REXA actuators were identified as part of the engineer's design. The actuators have been in service for more than ten years and have proven effective. To date, the maintenance of these valves has consisted of parts replacement due to normal wear. Some of the units that are located outdoors and exposed to the elements, have begun to show signs of failure due to corrosion, and are due for scheduled replacement. Because of the superior performance of the REXA actuators, staff recommends executing a sole source purchase agreement with REXA Electraulic Actuation, in an amount not to exceed \$235,000.

ATTACHMENTS

Attachment I	Staff Report
Attachment II	Resolution